

# **CE** 3 Port Solenoid Valve





#### Improved pilot valve


Pilot valve cover is stronger using stainless steel. Mounting thread is also reinforced from size M1.7 to M2.

Flow Characteristics

Carias	Flo	w characteristics		
Series	C [dm³/(s·bar)]	b	Cv	ø[ℓ/min(ANR)]
SYJ300	0.36	0.31	0.089	92
SYJ500	1.2	0.41	0.32	329
SYJ700	2.7	0.38	0.72	724

# Rubber Seal 3 Port Solenoid Valve Series SYJ300/500/700

Variations



Note) All AC voltage models have built-in surge voltage suppressor.

Front matter 1



# Series SYJ300/500/700

#### **Manifold Variations**

							A po	ort size				
	Valve series	A port	P, R ports					W	ith one-t	ouch fittir	ng	
	valve series	location	size	M3	M5	1/8		Ap	plicable	tubing O.	D.	
							ø4	ø6	ø8	N3	N7	N9
	SYJ300	Тор	M5	Note 1)	—			_	_	_		—
ted	510300	төр	1/8	Note 2)	—	—				_	—	—
<b>Body ported</b>	SYJ500	Тор	1/8	_	•	_	_	_	_			
BO	SYJ700	Тор	1/8			Note 1)						_
	515700	төр	1/4	—	_			_	_			_
_	SYJ300	Side	M5	Note 1)	—	—	_	—	_	_	—	_
Base mounted	513300	Side	1/8	—		_					_	
our	SYJ500	Bottom	1/8							—	_	—
e m	513300	Side	1/8	—				$\bullet$				_
as		Bottom	1/8		_	Note 1)	_					
m	<b>SYJ700</b>	Bolion	1/4				_					
		Side	1/4				—					

Note 1) Only for internal pilot Note 2) Only for external pilot

ル



Series SYJ300

Series SYJ500

Series SYJ700

# **Rubber Seal 3 Port Pilot Solenoid Valve** Series SYJ300

Refer to www.smcworld.com for details of products compatible with overseas standards.

#### Specifications



Body ported



Base mounted

Fluid		Air
Operating pressure range (MPa)	Internal pilot	0.15 to 0.7
Ambient and fluid ter	nperature (°C)	-10 to 50 (No freezing. Refer to back page 2.)
Response time ms (a	t 0.5 MPa) Note 1)	15 or less
Max. operating freque	ency (Hz)	10
Manual override (Mar	nual operation)	Non-locking push type, push-turn locking slotted type, push-turn locking lever type
Pilot exhaust method		Individual exhaust for the pilot valve, common exhaust for the pilot and main valve
Lubrication		Not required
Mounting orientation		Unrestricted
Shock/Vibration resis	stance (m/s <sup>2</sup> ) Note 2)	150/30
Enclosure		Dust proof (* M8 connector conforms to IP65.)
	lynamic performance te thout surge voltage sup stance: No malfunct	est, JIS B 8374-1981. (Coil temperature: 20°C, at rated opressor.) ion occurred when it is tested in the axial direction and at gles to the main valve and armature in both energised and


de-energised states every once for each condition. (Value in the initial state) No malfunction occurred in one sweep test between 45 and 2000 Hz. Vibration resistance: Test was performed to axis and right angle directions of the main valve and armature when pilot signal is ON and OFF. (Value in the initial state)

#### **Solenoid Specifications**

#### **JIS Symbol** Internal pilot

SYJ31<sup>2</sup>

SYJ32<sup>2</sup>




#### External pilot

à 1


(P)(R)


SYJ31<sup>2</sup><sub>4</sub>R











\* In common between 110 VAC and 115 VAC, and between 220 VAC and 230 VAC. \* For 115 VAC and 230 VAC, the allowable voltage is -15% to +5% of rated voltage. \* S, Z and T type (with power saving circuit) should be used within the following allowable voltage fluctuation range due to a voltage drop caused by the internal circuit. S and Z type: 24 VDC: -7% to +10%

12 VDC: -4% to +10% T type: 24 VDC: -8% to +10% 12 VDC: -6% to +10%

Made to Order (For details, refer to pages 57 through to 59.)

**GSMC** 

#### Flow Characteristics/Weight

		- <i>(</i>	<b>.</b>				Flow char	acteristics	;			Effective	V	Veight (g) Note	e)	
Valve i	model	Type of actuation	Port size		1→2 (P→A)				2→3 (	A→R)		area	Crommet	L/M plug	M8	
		actuation	size	C [dm <sup>3</sup> /(s bar)]	b	Cv	Q [d/min(ANR)]*	C [dm3/(s bar)]	b	Cv	Q [d/min(ANR)]*	(mm²)	Grommet	connector	connector	
Body	SYJ312	N.C.	M3 x 0.5	_	_	_	_	_	-	_	_	0.9	32	33	37	
ported	SYJ322	N.O.	WIS X 0.5	_	_	_	_	_	_	_	_	0.9	32	33	37	
Base mounted	SYJ314	N.C.	M5 x 0.8	0.41	0.18	0.086	97	0.35	0.33	0.086	91		53 (32)	F4 (00)	50 (07)	
(with sub-plate)	SYJ324	N.O.	0.0 X CIVI	0.36	0.31	0.089	92	0.36	0.31	0.089	92	_	55 (52)	54 (33)	58 (37)	

))

Note) (): Without sub-plate. \* These values have been calculated according to ISO 6358 and represent the flow rate measured in standard conditions at an upstream pressure of 0.6MPa (relative pressure) and a differential pressure of 0.1MPa.


#### **External Pilot**

#### **SYJ300R**

Pilot valve pressure is supplied separately from the main valve pressure through the use of a separate supply port. It can be used in the vacuum (up to -100 kPa) or low pressure line with 0.15 MPa or less.


#### Specifications

Applicable model	Base mounted	(SYJ314R, SYJ324R)
Operating pressure range	Main pressure	-100 kPa to 0.7
MPa	External pilot pressure	0.15 to 0.7




Note 1) For manifold base, refer to page 7. Note 2) External pilot type body ported valves (SYJ3D2R) can only be used on the manifold.

#### How to Order




#### Construction



#### **Component Parts**

No.	Description	Material	Note
1	Body	Zinc die-casted	White
2	Piston plate	Resin	White
3	End cover	Resin	White
4	Piston	Resin	-
5	Spool valve assembly	Aluminum, H-NBR	_


#### How to Order Pilot Valve Assembly



#### **Replacement Parts**


No.	Description	No.	Note
6	Sub-plate	SYJ300-9-1-Q	Zinc die-casted
7	Pilot valve	V111(T)-□□□□	

# How to Order Connector Assembly for L/M Plug Connector





4

#### **Body Ported**




L plug connector (L): SYJ3 2- L - M3-Q M plug connector (M): SYJ3□2-□M□□-M3-Q M8 connector (WO): SYJ3□2-□WO□□-M3-Q





**SMC** 




\* Refer to back page 10 for dimensions with connector cable.

5

#### **Base Mounted (With Sub-plate)**


#### Grommet (G), (H): SYJ3□4-□<sup>G</sup><sub>H</sub>□□-M5-Q





#### L plug connector (L): SYJ3□4-□L□□-M5-Q

M plug connector (M): SYJ3□4-□M□□-M5-Q

#### M8 connector (WO): SYJ3□4-□WO□□-M5-Q







\* Refer to back page 10 for dimensions with connector cable.

# Series SYJ300 Manifold Specifications





#### **Manifold Specifications**

Madal	For internal pilot	Type 20	Type 41, S41	Type 42, S42
Model	For external pilot	Type 20R	—	Type 42R, S42R
Manifold type			Single base	e/B mount
P (SUP), R (EXH)			Common SUP/	Common EXH
Valve stations			2 to 20 s	stations
A port	Location	Valve		Base
Porting specifications	Direction	Тор		Side
	P, R port	M5 1/8	- M5	1/8
Port size	A port	МЗ	МЗ	M5 C4 (One-touch fitting ø4)
	X port Note)	M5	—	M5



			Port	size			Flow characteristics										
	Monifold		101	5120		1→2 (	P→A)			2→3 (	(A→R)		Effective				
	Manifold		1(P), 3(R) Port	2(A) Port	C [dm³/(s bar)]	b	Cv	Q[t/min(ANR)]*	C [dm³/(s bar)]	b	Cv	Q[d/min(ANR)]*	area (mm²)				
Body ported for internal pilot	Type SS3YJ3-20	SYJ3⊡2	M5	М3	_	_	-	-	_	_	-	-	0.9				
	Type SS3YJ3- 41 S41	SYJ3⊡4	M5	М3	-	_	-	-	_	_	-	-	1.5				
Base mounted	Type SS3YJ3-42-M5	SYJ3⊡4	1/8	M5	0.31	0.17	0.075	73	0.32	0.11	0.072	73	_				
for internal pilot	Type SS3YJ3-42-C4	51304	1/8	C4	0.33	0.36	0.086	87	0.33	0.2	0.082	79	_				
	Type SS3YJ3-S42-M5			M5	0.32	0.3	0.079	81	0.33	0.35	0.086	87	_				
	Type SS3YJ3-S42-C4	SYJ3⊡4	1/8	C4	0.35	0.17	0.082	82	0.35	0.26	0.086	87	_				
Body ported for external pilot	Type SS3YJ3-20R	SYJ3⊡2R	1/8	МЗ	-	-	-	-	_	_	-	-	0.9				
	Type SS3YJ3-42R-M5		1/0	M5	0.31	0.17	0.075	73	0.32	0.11	0.072	73	_				
Base mounted	Type SS3YJ3-42R-C4	SYJ3⊡4R	1/8	C4	0.33	0.36	0.086	87	0.33	0.20	0.082	79	_				
for external pilot	Type SS3YJ3-S42R-M5		1/0	M5	0.32	0.30	0.079	81	0.33	0.35	0.086	87	—				
	Type SS3YJ3-S42R-C4	SYJ3⊡4R	1/8	C4	0.35	0.17	0.082	82	0.35	0.26	0.086	87	_				

Note) Value at manifold base mounted, 2 position single acting.

\* These values have been calculated according to ISO 6358 and represent the flow rate measured in standard conditions at an upstream pressure of 0.6MPa (relative pressure) and a differential pressure of 0.1MPa.


#### How to Order Manifold (Example)

Instruct by specifying the valves and blanking plate assembly to be mounted on the manifold along with the manifold base model no. (Example) SS3YJ3-20-03-Q······1 set (manifold base) \* SYJ312-5LZ-M3-Q······1 set (manifold base) \* SYJ300-10-1A-Q······1 set (valve) \* SYJ300-10-1A-Q······1 set (blanking plate assembly) → The asterisk denotes the symbol for assembly. Prefix it to the part nos. of the solenoid valve, etc.



#### Combinations of Solenoid Valve, Manifold Gasket and Manifold Base

Body ported (Type SYJ3□2(R)-Q)



Applicable base SS3YJ3-20-Q | Manifold SS3YJ3-20R-Q | base Base mounted (Type SYJ3□4(R)-Q) Round head combination screw SY100-33-3 (M1.7 x 17, Matt nickel plated) (M1.7 x 17, Matt nickel plated) Manifold gasket SYJ300-5-4 Applicable base

SS3YJ3-41-Q SS3YJ3-541-Q SS3YJ3-541-Q SS3YJ3-42-Q SS3YJ3-542-Q SS3YJ3-542-Q SS3YJ3-542R-Q SS3YJ3-542R-Q



#### Model no.: SYJ300-10-1A-Q Model no.: SYJ300-10-2A-Q Round head Round head combination screw combination screw Blanking plate Blanking plate Р Manifold gasket Manifold gasket Applicable base Applicable base

SS3YJ3-20-Q Manifold SS3YJ3-20R-Q base Applicable base Sub-plate SS3YJ3-41-Q SS3YJ3-541-Q SS3YJ3-42-Q SS3YJ3-42-Q SS3YJ3-542-Q SS3YJ3-42R-Q SS3YJ3-542R-Q


## \land Caution

Mounting screw tightening torques

M1.7: 0.12 N·m


Use caution to the assembly orientation for solenoid valves, gasket, and optional parts.

#### Manifold for Internal Pilot Type




SMC


#### Type 20 Manifold: Top Ported/SS3YJ3-20-Stations -00 (-F)-Q




#### L plug connector (L)



#### M plug connector (M)



#### M8 connector (WO)




\* Refer to back page 10 for dimensions with connector cable.

Station n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
L1	35.5	46	56.5	67	77.5	88	98.5	109	119.5	130	140.5	151	161.5	172	182.5	193	203.5	214	224.5
L2	28.5	39	49.5	60	70.5	81	91.5	102	112.5	123	133.5	144	154.5	165	175.5	186	196.5	207	217.5

#### Type 41 Manifold: Side Ported/SS3YJ3-41-Stations -M3-Q


#### Grommet (G)





L plug connector (L)



M8 connector (WO)









\* Refer to back page 10 for dimensions with connector cable.

Station n	Station 2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	Station 20
L1	35.5	46	56.5	67	77.5	88	98.5	109	119.5	130	140.5	151	161.5	172	182.5	193	203.5	214	224.5
L2	28.5	39	49.5	60	70.5	81	91.5	102	112.5	123	133.5	144	154.5	165	175.5	186	196.5	207	217.5



#### Type 20R Manifold: Top Ported (External Pilot Type)/SS3YJ3-20R-Stations-00 -Q


#### Grommet (G)





L plug connector (L)


M plug connector (M)

M8 connector (WO)










Station n	Station 2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	Station 20
L1	47.5	58	68.5	79	89.5	100	110.5	121	131.5	142	152.5	163	173.5	184	194.5	205	215.5	226	236.5
L2	39.5	50	60.5	71	81.5	92	102.5	113	123.5	134	144.5	155	165.5	176	186.5	197	207.5	218	228.5
L3	31.5	42	52.5	63	73.5	84	94.5	105	115.5	126	136.5	147	157.5	168	178.5	189	199.5	210	220.5



Type 42R Manifold: Side Ported (External Pilot Type)/SS3YJ3-42R-Stations-M5, N3 - Q

18.5

(A port) Applicable tubing O.D.:

# Rubber Seal 3 Port Pilot Solenoid Valve Series SYJ500

Refer to <u>www.smcworld.com</u> for details of products compatible with overseas standards.

#### Specifications



Body ported



Base mounted

Fluid		Air								
Operating pressure range (MPa)	Internal pilot	0.15 to 0.7								
Ambient and fluid ter	nperature (°C)	-10 to 50 (No freezing. Refer to back page 2.)								
Response time ms (a	t 0.5 MPa) <sup>Note 1)</sup>	25 or less								
Max. operating frequ	ency (Hz)	5								
Manual override (Ma	nual operation)	Non-locking push type, push-turn locking slotted type, push-turn locking lever type								
Pilot exhaust method	I	Individual exhaust for the pilot valve, common exhaust for the pilot and main valve								
Lubrication		Not required								
Mounting orientation		Unrestricted								
Shock/Vibration resis	stance (m/s <sup>2</sup> ) Note 2)	150/30								
Enclosure		Dust proof (* DIN terminal, M8 connector conforms to IP65.)								
<ul> <li>* Based on IEC60529</li> <li>Note 1) Based on dynamic performance test, JIS B 8374-1981. (Coil temperature: 20°C, at rated voltage, without surge voltage suppressor.)</li> <li>Note 2) Impact resistance: No malfunction occurred when it is tested in the axial direction and at the right angles to the main valve and armature in both energised and de-energised states every once for each condition.</li> </ul>										

and de-energised states every once for each condition. (Value in the initial state) Vibration resistance: No malfunction occurred in one sweep test between 45 and 2000 Hz. Test was performed to axis and right angle directions of the main valve and armature when pilot signal is ON and OFF. (Value in the initial state)

#### **Solenoid Specifications**

#### Grommet (G), (H), L plug connector (L), M plug connector (M), DIN terminal (D), **Electrical entry** M8 connector (W) G, H, L, M, W D **Coil rated** DC 24, 12, 6, 5, 3 24, 12 voltage (V) AC 50/60 Hz 100, 110, 200, 220 Allowable voltage fluctuation ±10% of rated voltage \* Standard 0.35 (With light: 0.4 (DIN terminal with light: 0.45)) Power With power DC consumption (W) 0.1 (With light only) saving circuit 0.78 (With light: 0.87) 100 V 0.86 (With light: 0.97) 110 V [0.94 (With light: 1.07)] [115 V] Apparent power AC 1.15 (With light: 1.30) 200 V (VA) \* 1.27 (With light: 1.46) 220 V [1.39 (With light: 1.60)] [230 V] Surge voltage suppressor Diode (DIN terminal, varistor when non-polar types) Indicator light LED (Neon light when AC with DIN terminal)

\* In common between 110 VAC and 115 VAC, and between 220 VAC and 230 VAC.

Made to Order (For details, refer to pages 57 through to 59.) For 115 VAC and 230 VAC, the allowable voltage is –15% to +5% of rated voltage.
 \* S, Z and T type (with power saving circuit) should be used within the following allowable voltage fluctuation range due to a voltage drop caused by the internal circuit.


S and Z type: 24 VDC: -7% to +10%

12 VDC: -4% to +10% T type: 24 VDC: -8% to +10%


24 VDC: -8% to +10% 12 VDC: -6% to +10%

JIS Symbol

### Internal pilot



#### External pilot





#### Flow Characteristics/Weight

	Turno o		Turna af Davrt	Flow characteristics									Weight (g) Note)					
Valve m	nodel	Type of actuation	Port size		1→2 (P	→A)			2→3 (/	A→R)		Grommet	L/M plug	DIN	M8			
		actuation	5126	C [dm3/(s bar)]	b	Cv	Q[t/min(ANR)]*	C [dm3/(s bar)]	b	Cv	Q[t/min(ANR)]*	Grommer	connector	terminal	connector			
Body	SYJ512	N.C.	M5	0.53	0.45	0.14	150	0.47	0.39	0.12	127	46	47	68	51			
ported	SYJ522	N.O.	IVIS	0.66	0.45	0.18	186	0.66	0.45	0.18	186	40						
Base mounted	SYJ514	N.C.	1 /0	1.2	0.41	0.32	329	1.1	0.46	0.32	313	co (4c)	(1/47)	00 (00)				
(with sub-plate)	SYJ524	N.O.	1/8	1.3	0.37	0.33	346	1.2	0.48	0.34	347	60 (46)	61 (47)	82 (68)	65 (51)			

Note) Value for DC. Add 1 g for AC. ( ): Without sub-plate.

\* These values have been calculated according to ISO 6358 and represent the flow rate measured in standard conditions at an upstream pressure of 0.6MPa (relative pressure) and a differential pressure of 0.1MPa.

#### **External Pilot**


#### SYJ500R

Pilot valve pressure is supplied separately from the main valve pressure through the use of a separate supply port. It can be used in the vacuum (up to -100 kPa) or low pressure line with 0.15 MPa or less.


#### **Specifications**

Applicable model
Operating pressure range
MPa
P, R port M5 X port (External pilot) M5 Note 1) Note 2)

#### How to Order




#### Construction



#### **Component Parts**

No.	Description	Material	Note
1	Body	Aluminum die-casted	White
2	Piston plate	Resin	White
3	End cover	Aluminum die-casted	White
4	Piston	Resin	-
5	Spool valve assembly	-	_
6	Spool spring	Stainless steel	_


#### How to Order Pilot Valve Assembly




#### **Replacement Parts**

No.	Description	No.	Note
7	Sub-plate	SYJ500-9-1-Q	Zinc die-casted
8	Pilot valve	V111(T)-□□□□	
_	Bracket assembly	SYJ5000-13-3A	

#### How to Order Connector Assemby for L/M Plug Connector



#### **Body Ported**



**SMC** 

14.5

20

23

27

3

14.5

20

23

\* Refer to back page 10 for dimensions with connector cable.

3

14.5 3

20

23


14.5 3

20


23

#### **Base Mounted (With Sub-plate)**

#### Grommet (G), (H): SYJ5□4-□<sup>G</sup><sub>H</sub>□□-01□-Q



L plug connector (L):	M plug connector (M):	DIN terminal (D):	M8 connector (WO):
SYJ5□4-□L□□-01□-Q	SYJ5⊡4-⊡M⊡⊒-01⊡-Q	SYJ5⊡4-⊡D⊡⊡-01⊡-Q	SYJ5⊡4-⊡WO□□-01□-Q



 Refer to back page 10 for dimensions with connector cable.

# Series SYJ500 Manifold Specifications





	Ear internal pilot	Turne 20	Tune 40	Turne 41						
Model	For internal pilot	Type 20	Type 40	Type 41						
Woder	For external pilot	Type 21R	Type 40R	Type 41R						
Manifold type		Single base/B mount								
P (SUP), R (EX	H)		Common SUP,	common EXH						
Valve stations			2 to 20 s	stations						
A port Porting	Location	Valve		Base						
specifications	Direction	Тор	Bottom	Side						
	P, R port	1/8	1/8	1/8						
Port size	A port	M5	M5 1⁄8	M5 x 0.8, $\frac{1}{8}$ , C4 (One-touch fitting for ø4), C6 (One-touch fitting for ø6)						
	X port Note)	M5	M5	M5						

Note) Only for external pilot

#### **Flow Characteristics**

			Port	0170				Flow char	acteristics				
			For	SIZE		1→2 (	P→A)		2→3 (A→R)				
Ma	anifold		1(P), 3(R) port	2(A) port	C [dm³/(s·bar)]	b	Cv	Q[ℓ/min(ANR)]*	C [dm³/(s·bar)]	b	Cv	Q[d/min(ANR)]*	
Body ported for internal pilot	Type SS3YJ5-20	SYJ5⊡2	1/8	M5	0.47	0.43	0.13	131	0.74	0.32	0.19	191	
	Type SS3YJ5-40-M5		1/8	M5	0.71	0.52	0.21	212	0.81	0.28	0.20	203	
	Type SS3YJ5-40-01		1/8	1/8	0.98	0.36	0.25	259	0.92	0.24	0.22	226	
Base mounted	Type SS3YJ5-41-M5	SYJ5⊡4	1/8	M5	0.71	0.49	0.20	207	0.80	0.23	0.19	195	
for internal pilot	Type SS3YJ5-41-01		1/8	1/8	1.0	0.37	0.26	266	0.96	0.25	0.24	237	
	Type SS3YJ5-41-C4		1/8	C4	0.68	0.35	0.17	179	1.0	0.25	0.24	247	
	Type SS3YJ5-41-C6		1/8	C6	1.0	0.27	0.25	250	1.0	0.30	0.26	254	
Body ported for external pilot	Type SS3YJ5-21R	SYJ5□2R	1/8	M5	0.47	0.43	0.13	131	0.74	0.32	0.19	191	
	Type SS3YJ5-40R-M5		1/8	M5	0.71	0.52	0.21	212	0.81	0.28	0.20	203	
	Type SS3YJ5-40R-01		1/8	1/8	0.98	0.36	0.25	259	0.92	0.24	0.22	226	
Base mounted	Type SS3YJ5-41R-M5	SYJ5⊡4R	1/8	M5	0.71	0.49	0.20	207	0.80	0.23	0.19	195	
for external pilot	Type SS3YJ5-41R-01	51J3L4K	1/8	1/8	1.0	0.37	0.26	266	0.96	0.25	0.24	237	
1	Type SS3YJ5-41R-C4		1/8	C4	0.68	0.35	0.17	179	1.0	0.25	0.24	247	
	Type SS3YJ5-41R-C6		1/8	C6	1.0	0.27	0.25	259	1.0	0.30	0.26	254	

Note) Value at manifold base mounted, 2 position single operating.

\* These values have been calculated according to ISO 6358 and represent the flow rate measured in standard conditions at an upstream pressure of 0.6MPa (relative pressure) and a differential pressure of 0.1MPa.

#### How to Order Manifold (Example)


Instruct by specifying the valves and blanking plate as with the manifold base model no.	ssembly to be mounted on the manifold along
(Example)	
SS3YJ5-20-03-Q ······1 set (manifold base)	SS3YJ5-41R-03-C6-Q ····1 set (manifold base)
* SYJ512-5LZ-M5-Q 2 sets (valve)	SYJ514R-5G-Q······ 2 sets (valve)
* SYJ500-10-1A-Q $\cdots$ 1 set (blanking plate assembly) $\top$	SYJ500-10-3A-Q 1 set (blanking plate assembly)
→ The asterisk denotes the symbol for assembly. Prefix	it to the part nos. of the solenoid valve, etc.




#### Combinations of Solenoid Valve, Manifold Gasket and Manifold Base

#### Body ported (Type SYJ5□2(R))-Q

#### Base mounted (Type SYJ5□4(R))-Q




Applicable base SS3YJ5-21R-Q SS3YJ5-20-Q Manifold base




#### Applicable base Sub-plate SS3YJ5-40-Q SS3YJ5-41-Q Mai

SS3YJ5-41-Q Manifold SS3YJ5-40R-Q base SS3YJ5-41R-Q **Blanking Plate Assembly** 



#### Model no.: SYJ500-10-1A-Q




\land Caution

Mounting screw tightening torques

M2.5: 0.45 N·m

Use caution to the assembly orientation for solenoid valves (blanking plate) and manifold gasket.


#### Manifold for Internal Pilot Type



*S*MC *∞* 

#### Type 20 Manifold: Top Ported/SS3YJ5-20-Stations-00 (-F)-Q

#### Grommet (G)




L plug connector (L)

M plug connector (M)

**DIN terminal (D)** 


M8 connector (WO)








Station n	Station 2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	Station 20
L1	53	69	85	101	117	133	149	165	181	197	213	229	245	261	277	293	309	325	341
L2	40	56	72	88	104	120	136	152	168	184	200	216	232	248	264	280	296	312	328
L3	16	32	48	64	80	96	112	128	144	160	176	192	208	224	240	256	272	288	304
L4	8	24	40	56	72	88	104	120	136	152	168	184	200	216	232	248	264	280	296


#### Type 40 Manifold: Bottom Ported/SS3YJ5-40-Stations -M5, 01□-Q












₽*	Refer to back page 10 for dimensions with connector
	dimensions with connector cable.

Port size	Station n	Station 2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	Station 20
ME	L1	52	68	84	100	116	132	148	164	180	196	212	228	244	260	276	292	308	324	340
M5	L2	43	59	75	91	107	123	139	155	171	187	203	219	235	251	267	283	299	315	331
1/8	L1	63	80	97	114	131	148	165	182	199	216	233	250	267	284	301	318	335	352	369
	L2	54	71	88	105	122	139	156	173	190	207	224	241	258	275	292	309	326	343	360

## Type 41 Manifold: Side Ported/SS3YJ5-41-Stations -C4, N3 C-Q

#### Grommet (G)





L plug connector (L)


M plug connector (M)


**DIN terminal (D)** 

M8 connector (WO)










$\mathcal{P}^*$	Refer to back page 10 for dimensions with connector cable.
	caple.


Port size	Station n	Station 2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	Station 20
One-touch	L1	50	66	82	98	114	130	146	162	178	194	210	226	242	258	274	290	306	322	338
fitting	L2	41	57	73	89	105	121	137	153	169	185	201	217	233	249	265	281	297	313	329


## Type 41 Manifold: Side Ported/SS3YJ5-41-Stations -M5, 01 □-Q


#### Grommet (G) For M5

#### For 1/8










Port size	Station n	Station 2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	Station 20
ME	L1	52	68	84	100	116	132	148	164	180	196	212	228	244	260	276	292	308	324	340
M5	L2	43	59	75	91	107	123	139	155	171	187	203	219	235	251	267	283	299	315	331
1/8	L1	53	70	87	104	121	138	155	172	189	206	223	240	257	274	291	308	325	342	359
1/0	L2	44	61	78	95	112	129	146	163	180	197	214	231	248	265	282	299	316	333	350

#### Type 21R Manifold: Top Ported (External Pilot Type)/SS3YJ5-21R-Stations-00 -Q

#### Grommet (G)





L plug connector (L)


M plug connector (M)


**DIN terminal (D)** 

M8 connector (WO)










\* Refer to back page 10 for dimensions with connector cable.

Station n	Station 2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	Station 20
L1	62	78	94	110	126	142	158	174	190	206	222	238	254	270	286	302	318	334	350
L2	53	69	85	101	117	133	149	165	181	197	213	229	245	261	277	293	309	325	341
L3	47	63	79	95	111	127	143	159	175	191	207	223	239	255	271	287	303	319	335

#### Type 40R Manifold: Bottom Ported (External Pilot Type)/SS3YJ5-40R-Stations-M5, 01D-Q





L plug connector (L) M

M plug connector (M)

**DIN terminal (D)** 

M8 connector (WO)






49 49 49 49 40 41.1 M8 x 1 58.6

	Refer to back page 10 for dimensions with connector cable.
--	--

D. I. I.	01-1-1-1	04-4-1-0	0	4	F	0	7	0	0	40		10	10		45	10	47	10	10	01-1
Port size	Station n	Station 2	3	4	5	6	1	8	9	10	11	12	13	14	15	16	17	18	19	Station 20
	L1	62	78	94	110	126	142	158	174	190	206	222	238	254	270	286	302	318	334	350
M5	L2	53	69	85	101	117	133	149	165	181	197	213	229	245	261	277	293	309	325	341
	L3	47	63	79	95	111	127	143	159	175	191	207	223	239	255	271	287	303	319	335
	L1	63	80	97	114	131	148	165	182	199	216	233	250	267	284	301	318	335	352	369
1/8	L2	54	71	88	105	122	139	156	173	190	207	224	241	258	275	292	309	326	343	360
	L3	48	65	82	99	116	133	150	167	184	201	218	235	252	269	286	303	320	337	354

## Type 41R Manifold: Side Ported (External Pilot Type)/SS3YJ5-41R-Stations - C4, N3 -


#### Grommet (G)



L plug connector (L) M plug connector (M)



M8 connector (WO)





dimensions with connector cable.

Port size	Station n	Station 2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	Station 20
One touch	L1	58	74	90	106	122	138	154	170	186	202	218	234	250	266	282	298	314	330	346
One-touch fitting	L2	49	65	81	97	113	129	145	161	177	193	209	225	241	257	273	289	305	321	337
intang	L3	43	59	75	91	107	123	139	155	171	187	203	219	235	251	267	283	299	315	331


#### Type 41R Manifold: Side Ported (External Pilot Type)/SS3YJ5-41R-Stations -M5, 01□-Q


#### For M5





#### For 1/8





Port size	Station n	Station 2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	Station 20
	L1	62	78	94	110	126	142	158	174	190	206	222	238	254	270	286	302	318	334	350
M5	L2	53	69	85	101	117	133	149	165	181	197	213	229	245	261	277	293	309	325	341
	L3	47	63	79	95	111	127	143	159	175	191	207	223	239	255	271	287	303	319	335
	L1	63	80	97	114	131	148	165	182	199	216	233	250	267	284	301	318	335	352	369
1/8	L2	54	71	88	105	122	139	156	173	190	207	224	241	258	275	292	309	326	343	360
	L3	48	65	82	99	116	133	150	167	184	201	218	235	252	269	286	303	320	337	354

# **Rubber Seal 3 Port Pilot Solenoid Valve** Series SYJ700

Internal pilot

voltage, without surge voltage suppressor.)

Refer to www.smcworld.com for details of products compatible with overseas standards.

Air

0.15 to 0.7

-10 to 50 (No freezing. Refer to back page 2.)

30 or less

5 Non-locking push type, push-turn locking slotted

type, push-turn locking lever type

Individual exhaust for the pilot valve,

common exhaust for the pilot and main valve

Not required

Unrestricted

150/30

Dust proof (\* DIN terminal, M8 connector: IP65)

No malfunction occurred when it is tested in the axial direction and at the right angles to the main valve and armature in both energised

Test was performed to axis and right angle directions of the main valve

and de-energised states every once for each condition.

Vibration resistance: No malfunction occurred in one sweep test between 45 and 2000 Hz.

and armature when pilot signal is ON and OFF.



**Operating pressure** 

**Pilot exhaust method** 

Mounting orientation

Ambient and fluid temperature (°C)

Max. operating frequency (Hz)

\* Based on IEC60529

Note 2) Impact resistance:

Response time ms (at 0.5 MPa) Note 1)

Manual override (Manual operation)

Shock/Vibration resistance (m/s<sup>2</sup>) Note 2)

range (MPa)

Lubrication

Enclosure

Fluid




Body ported



Base mounted

#### JIS Symbol

#### Internal pilot



#### **Solenoid Specifications**

Electrical entry			M plug connector (N	. plug connector (L), /), DIN terminal (D), ector (W)					
			G, H, L, M, W	D					
Coil rated	D	С	24, 12, 6, 5, 3	24, 12					
voltage (V)	A	C 50/60 Hz	-	100, 110, 200, 220					
Allowable voltage	fluctu	ation	±10% of rate	ed voltage *					
Power		Standard	0.35 (With light: 0.4 (DIN terminal with light: 0.45))						
consumption (W)	DC	With power saving circuit	0.1 (With	light only)					
		100 V	-	0.78 (With light: 0.87)					
Apparent power		110 V [115 V]	-	0.86 (With light: 0.97) [0.94 (With light: 1.07)]					
(VA) *	AC	200 V	-	1.15 (With light: 1.30)					
		220 V [230 V]	-	1.27 (With light: 1.46) [1.39 (With light: 1.60)]					
Surge voltage sup	press	or	Diode (DIN terminal, varistor when non-polar types)						
Indicator light			LED (Neon light when AC with DIN terminal)						
* For 115 VAC * S, Z and T ty	and 23 pe (wit	30 VAC, the allo h power saving o	15 VAC, and between 220 ' wable voltage is -15% to +5 circuit) should be used within oltage drop caused by the in	% of rated voltage. n the following allowable					


Note 1) Based on dynamic performance test, JIS B 8374-1981. (Coil temperature: 20°C, at rated

(Value in the initial state)

(Value in the initial state)

#### SYJ71<sup>2</sup><sub>4</sub>R

External pilot



Made to Order

SYJ72<sup>2</sup><sub>4</sub>R

(For	details,	refer	to	pages	57	through

to 59.)

12 VDC: -4% to +10%

T type: 24 VDC: -8% to +10%

12 VDC: -6% to +10%

S and Z type: 24 VDC: -7% to +10%



### Flow Characteristics/Weight

		<b>-</b> (	<b>.</b> .				Flow char	acteristics					Weight (	g) Note)	
Valve m	nodel	Type of actuation	Port size		1→2 (P	→A)			2→3 (A	.→R)		Grommet	L/M plug	DIN	M8
		actuation	SIZE	C [dm <sup>3</sup> /(s bar)]	b	Cv	Q[d/min(ANR)]*	C [dm3/(s bar)]	b	Cv	Q[t/min(ANR)]*	Giommer	connector	terminal	connector
Body	SYJ712	N.C.	1/8	2.8	0.43	0.77	779	2.5	0.51	0.76	741	75	76	97	80
ported	SYJ722	N.O.	1/0	2.7	0.38	0.72	724	2.4	0.42	0.69	662	75	76	97	00
	SYJ714	N.C.	1/8	2.9	0.32	0.71	747	2.7	0.34	0.69	705				
Base mounted		N.O.	1/0	2.8	0.21	0.70	674	2.3	0.45	0.63	649	135 (75)	136 (76)	157 (97)	140 (80)
(with sub-plate)	SYJ714	N.C.	1/4	3.0	0.31	0.74	768	2.6	0.33	0.66	674	135 (75)	130 (70)	157 (97)	140 (80)
	plate) SYJ714 SYJ724	N.O.	1/4	2.7	0.31	0.68	691	2.3	0.48	0.64	665				

Note) Value for DC. Add 3 g for AC. ( ): Without sub-plate. \* These values have been calculated according to ISO 6358 and represent the flow rate measured in standard conditions at an upstream pressure of 0.6MPa (relative pressure) and a differential pressure of 0.1MPa.


### **External Pilot**

### **SYJ700R**

Pilot valve pressure is supplied separately from the main valve pressure through the use of a separate supply port. It can be used in the vacuum (up to -100 kPa) or low pressure line with 0.15 MPa or less.


### **Specifications**

Applicable model	Base mounted (S	SYJ714R, SYJ724R)
Operating pressure range	Main pressure	–100 kPa to 0.7
MPa	External pilot pressure	0.15 to 0.7



### Series SYJ700

### How to Order



Note

Aluminum

die-casted


1/8


1/4

### Construction

(A)

3 1





No.

SYJ700-9-1-Q

SYJ700-9-2-Q

V111(T)-000

SYJ700-19-1A

for L/M Plug Connector

How to Order Connector Assembly

#### **Component Parts**

No.	Description	Material	Note
1	Body	Aluminum die-casted	White
2	Piston plate	Resin	White
3	End cover	Aluminum die-casted	White
4	Piston	Resin	_
5	Spool valve assembly	-	_
6	Spool spring	Stainless steel	-

### How to Order Pilot Valve Assembly

#### For DC: SY100-30-4A-5 V111 G Without lead wire: (with connector and SY100-30-A Light/surge voltage suppressor **Coil specifications** 2 of sockets only) Without light/surge voltage suppressor -Standard s With surge voltage suppressor With power saving circuit Lead wire length т With light/surge voltage suppressor Ζ (24, 12 VDC only) R With surge voltage suppressor (Non-polar type) 300 mm Power saving circuit is not available in the **U** With light/surge voltage suppressor (Non-polar type) 6 600 mm 10 15 Power saving circuit is only available in the 1000 mm case of W□ type. "Z" type. 1500 mm 20 25 2000 mm Rated voltage 2500 mm 24 VDC 5 30 3000 mm 12 VDC 6 V 50 5000 mm Electrical entry 6 VDC 5 VDC S R G Grommet, 300 mm lead wire 3 VDC Grommet, 600 mm lead wire н L With lead wire L plug LN Without lead wire connector LO Without connector Note 1) Enter the cable length With lead wire М symbols in □. Please M plug MN Without lead wire be sure to fill in the connector мо Without connector blank referring to back **WO** M8 page 10. Without connector cable connector With connector cable Note 1) W□ How to Order M8 Connector Cable For connector cable of M8 connector, refer to back page 9. V100-49-1-5 V115-D Rated voltage Light/surge voltage suppressor 24 VDC Without light/surge voltage suppressor 5 Cable length 12 VDC 6 With surge voltage suppressor (Non-polar type) S 100 VAC 50/60 Hz 1 With light/surge voltage suppressor (Non-polar type) 300 mm z 1 2 200 VAC 50/60 Hz 2 3 500 mm DOZ is not available. 110 VAC 50/60 Hz For AC voltage valves there is no "S" option. It is already built-in to the rectifier circuit. 1000 mm 3 [115 VAC 50/60 Hz] 4 2000 mm 220 VAC 50/60 Hz 5000 mm 4 Electrical entry [230 VAC 50/60 Hz] D DIN With connector DC specifications of type D and DO is only available DO terminal Without connector with 12 and 24 VDC. Do not replace V111 (G, H, L, M, W) to V115 (DIN terminal) Power saving circuit is not and vice versa when replacing pilot valve assembly only. available in the case of D or DO type.

No.

7

8

Description


Bracket assembly

Sub-plate

Pilot valve


SMC

### **Body Ported**



 L plug connector (L):
 M plug connector (M):
 DIN terminal (D):
 M8 connector (WO):

 SYJ7 2- L - 01 - (-F)-Q
 SYJ7 2- M - 01 - (-F)-Q
 SYJ7 2- D - 01 - 01 - (-F)-Q
 SYJ7 2- WO - 01 - (-F)-Q





\* Refer to back page 10 for dimensions with connector cable.




### **Base Mounted (With Sub-plate)**

### Grommet (G), (H): SYJ7 4-







 Refer to back page 10 for dimensions with connector cable.



## Series SYJ700 Manifold Specifications





Madal	For internal pilot	Type 20	Type 21	Type 40	Type 41	Type 42
Model	For external pilot		Type 21R	—	Type 41R	Type 42R
Manifold typ	e			Single base/E	8 mount	
P (SUP), R	(EXH)		Con	nmon SUP, co	mmon EXH	
Valve statio	ns			2 to 20 sta	tions	
A port Porting	Location	Valve	Valve	Base	Base	Base
specifications	Direction	Тор	Тор	Bottom	Bottom	Side
	P, R port	1/8	1/4	1/8	1/4	1/4
Port size	A port	1/8	1/ <sub>8</sub>	1⁄8	1/8	
	X port Note)	_	M5	—	M5	M5

### **Flow Characteristics**

			Deut	-!				Flow char	acteristics			
	la un life a la l		Port	size		1→2 (	P→A)			2→3	(A→R)	
IVI	lanifold		1(P), 3(R) port	2(A) port	C [dm³/(s·bar)]	b	Cv	Q[d/min(ANR)]*	C [dm³/(s·bar)]	b	Cv	Q[t/min(ANR)]*
Body ported	Type SS3YJ7-20	SYJ7⊡2	1/8	1/8	2.2	0.34	0.55	574	2.3	0.27	0.59	574
for internal pilot	Type SS3YJ7-21	515702	1/4	1/8	2.2	0.39	0.59	594	2.4	0.32	0.62	618
	Type SS3YJ7-40		1/8	1/8	2.1	0.35	0.59	552	2.3	0.27	0.54	574
Base mounted	Type SS3YJ7-41		1/4	1/8	2.2	0.35	0.59	578	2.4	0.36	0.66	635
for internal pilot	Type SS3YJ7-42-01	SYJ7⊡4	1/4	1/8	2.0	0.27	0.47	499	2.2	0.32	0.56	567
	Type SS3YJ7-42-C6		1/4	C6	1.6	0.32	0.39	412	2.2	0.27	0.54	549
	Type SS3YJ7-42-C8		1/4	C8	2.1	0.24	0.51	515	2.3	0.31	0.59	589
Body ported for external pilot	Type SS3YJ7-21R	SYJ7⊡2R	1/4	1/8	2.2	0.34	0.55	574	2.4	0.32	0.62	618
	Type SS3YJ7-41R		1/4	1/8	2.2	0.35	0.59	578	2.4	0.36	0.66	635
Base mounted	Type SS3YJ7-42R-01		1/4	1/8	2.0	0.27	0.47	499	2.2	0.32	0.56	567
for external pilot	Type SS3YJ7-42R-C6	SYJ7⊡4R	1/4	C6	1.6	0.32	0.39	412	2.2	0.27	0.54	549
	Type SS3YJ7-42R-C8		1/4	C8	2.1	0.24	0.51	515	2.3	0.31	0.59	589

Note) Only for external pilot

Note) Value at manifold base mounted, 2 position single operating.

\*These values have been calculated according to ISO 6358 and represent the flow rate measured in standard conditions at an upstream pressure of 0.6MPa (relative pressure) and a differential pressure of 0.1MPa.

### How to Order Manifold (Example)


Instruct by specifying the valves and blanking plate assembly to be mounted on the manifold along with the manifold base model no.
(Example)
SS3YJ7-20-03-Q ··········1 set (manifold base)
SS3YJ7-42R-03-01-Q ····1 set (manifold base)
The asterisk denotes the symbol for assembly. Prefix it to the part nos. of the solenoid valve, etc.




### Combinations of Solenoid Valve, Manifold Gasket and Manifold Base

### Body ported (Type SYJ7□2-Q)

Base mounted (Type SYJ7□4-Q)



### **Blanking Plate Assembly**



SS3YJ7-41-Q SS3YJ7-42-Q SS3YJ7-41R-Q SS3YJ7-42R-Q

\land Caution


Mounting screw tightening torques

M3: 0.8 N⋅m

Use caution to the assembly orientation for solenoid valves, gasket, and optional parts.


### Series SYJ700

### Manifold for Internal Pilot Type



### Type 20 Manifold: Top Ported/SS3YJ7-20-Stations (-00 )-Q

### Grommet (G)




L plug connector (L)

M plug connector (M)

DIN terminal (D)


### M8 connector (WO)



Station n	Station 2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	Station 20
L1	59	78	97	116	135	154	173	192	211	230	249	268	287	306	325	344	363	382	401
L2	49	68	87	106	125	144	163	182	201	220	239	258	277	296	315	334	353	372	391

### Type 21 Manifold: Top Ported/SS3YJ7-21-Stations (-00 )-Q

### Grommet (G)




L plug connector (L)


M plug connector (M)


 $\bigcirc$ 

**DIN terminal (D)** 

M8 connector (WO)







\* Refer to back page 10 for dimensions with connector cable.


Station n	Station 2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	Station 20
L1	61	80	99	118	137	156	175	194	213	232	251	270	289	308	327	346	365	384	403
L2	49	68	87	106	125	144	163	182	201	220	239	258	277	296	315	334	353	372	391

**SMC** 

### Series SYJ700

### Type 40 Manifold: Bottom Ported/SS3YJ7-40-Stations-01 -Q

### Grommet (G)





### L plug connector (L)


M plug connector (M)


DIN terminal (D)

### M8 connector (WO)









\* Refer to back page 10 for dimensions with connector cable.


Station n	Station 2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	Station 20
L1	59	78	97	116	135	154	173	192	211	230	249	268	287	306	325	344	363	382	401
L2	49	68	87	106	125	144	163	182	201	220	239	258	277	296	315	334	353	372	391

### Type 42 Manifold: Side Ported/SS3YJ7-42-Stations -01, C6, N7 -Q


### Grommet (G)

For C6, N7 C (Built-in one-touch fitting)

### For 1/8



(Station n) ----- (Station 1)




Station n	Station 2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	Station 20
L1	61	80	99	118	137	156	175	194	213	232	251	270	289	308	327	346	365	384	403
L2	49	68	87	106	125	144	163	182	201	220	239	258	277	296	315	334	353	372	391


**SMC** 

### Type 41 Manifold: Bottom Ported/SS3YJ7-41-Stations-01 -Q

### Grommet (G)




(Light/surge voltage suppressor)



### Series SYJ700

### Type 21R Manifold: Top Ported (External Pilot Type)/SS3YJ7-21R-Stations (-00 )-Q

### Grommet (G)




L plug connector (L)

M plug connector (M)

DIN terminal (D)

### M8 connector (WO)




Station n	Station 2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	Station 20
L1	61	80	99	118	137	156	175	194	213	232	251	270	289	308	327	346	365	384	403
L2	49	68	87	106	125	144	163	182	201	220	239	258	277	296	315	334	353	372	391

**SMC** 

### Type 42R Manifold: Side Ported/SS3YJ7-42R-Stations -01, C6, N7 -Q

### Grommet (G)


### For 1/8





L plug connector (L) M plug connector (M)

**DIN terminal (D)** 

M8 connector (WO)








 Refer to back page 10 for dimensions with connector cable.

Station n	Station 2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	Station 20
L1	61	80	99	118	137	156	175	194	213	232	251	270	289	308	327	346	365	384	403
L2	49	68	87	106	125	144	163	182	201	220	239	258	277	296	315	334	353	372	391


### Series SYJ700

### Type 41R Manifold: Bottom Ported (External Pilot Type)/SS3YJ7-41R-Stations-01D-Q

### Grommet (G)




(Light/surge voltage suppressor)





# 3 Port/Air Operated Valve Series SYJA300

How to Order



### How to Order Manifold Base

Same manifolds as series SYJ300 are prepared.

**SS3YJA3** – Fill the same as SS3YJ3.


\* Instruct by specifying the valves and blanking plate assembly to be mounted on the manifold along with the manifold base model no.

(Ex.) SS3YJA3-41-03-M3 ····	1 set
* SYJA314	1 set
* SYJA324	······ 1 set
<u>∗</u> SYJ300-10-2A ·····	1 set

The asterisk denotes the symbol for assembly. Prefix it to the part nos. of the solenoid valve, etc.

### Series SYJA300

### **Compact and lightweight**



Body ported

### Specifications


Fluid	Air
Operating pressure range (MPa)	0.15 to 0.7
Pilot pressure range (MPa) Note 1)	Operating pressure range to 0.7
Ambient and fluid temperature (°C)	-10 to 50 (No freezing. Refer to back page 2.)
Lubrication	Not required
Mounting orientation	Unrestricted
Impact/Vibration resistance (m/s <sup>2</sup> ) Note 2)	150/30

Note 1) Be certain that pressure within operating pressure range be supplied to supply port, because return pressure is introduced from supply port {1(P)} for activation. Note 2) Impact resistance: No malfunction resulted from the impact test using a drop impact tester.

Note 2) Impact resistance: No malfunction resulted from the impact test using a drop impact tester. The test was performed on the axis and right angle directions of the main valve, when pilot signal is ON and OFF. (Value in the initial state)

Vibration resistance: No malfunction occurred in one sweep test between 45 and 2000 Hz. Test was performed to axis and right angle directions of the main valve when pilot signal is ON and OFF. (Value in the initial state)

### With Bracket



### Flow Characteristics/Weight

			Flow characteristics							Pilot port size	Weight (g)	Effective		
Valve	Valve model Type of Port actuation size		1→2 (P→A)			2→3 (A→R)						area		
		actuation	5120	C [dm <sup>3</sup> /(s bar)]	b	Cv	Q[d/min(ANR)]*	C [dm <sup>3</sup> /(s bar)]	b	Cv	Q[//min(ANR)]*	3126		(mm²)
Body	SYJA312-M3	N.C.	МЗ	_	_	-	-	-		_	-		10	
ported	SYJA322-M3	N.O.	IVIS	_	_	-	-	-	Ι	_	-		18	0.9
Base mounted	SYJA314-M5	N.C.		0.41	0.18	0.086	97	0.35	0.33	0.086	97	M3	39	
(with sub-plate)	SYJA324-M5	N.O.	M5	0.36	0.31	0.089	92	0.36	0.31	0.089	92		(Without sub- plate 18)	-

Note) Model No. for base mounted style without sub-plate is SYJA3<sup>1</sup><sub>2</sub>4.


\*These values have been calculated according to ISO 6358 and represent the flow rate measured in standard conditions at an upstream pressure of 0.6MPa (relative pressure) and a differential pressure of 0.1MPa.




### Series SYJA300

### Dimensions

### Body ported: SYJA3□2-M3(-F)




### Base mounted: SYJA3 4-M5



# <sup>3</sup> Port/Air Operated Valve Series SYJA500/700

### How to Order



### How to Order Manifold Base

Same manifolds as series SYJ500/700 are prepared.


(For SYJA500)	SS3YJA5 -	Fill the same as SS3YJ5.
(For SYJA700)	SS3YJA7 -	Fill the same as SS3YJ7.

\* Instruct by specifying the valves and blanking plate assembly to be mounted on the manifold along with the manifold base model no.

(Ex.) SS3YJA5-40-03-01	1 set	(Ex.) SS3YJA7-41-03-01 1 set
* SYJA514	2 sets	* SYJA714 2 sets
<u>*</u> SYJ500-10-3A ·····	1 set	* SYJ700-10-2A 1 set

→ The asterisk denotes the symbol for assembly. Prefix it to the part nos. of the solenoid valve, etc.

### Series SYJA500/700



### Flow Characteristics/Weight

		Trace ( Deat			Flow characteristics							Dilatant	
		Type of actuation	Port size	1→2 (P→A)			2→3 (A→R)				Pilot port size	Weight (g)	
	actuation		5126	C [dm3/(s bar)]	b	Cv	Q[d/min(ANR)]*	C [dm <sup>3</sup> /(s bar)]	b	Cv	Q[t/min(ANR)]*	5126	
De du ve entre d	SYJA512-M5	N.C.	M5	0.53	0.45	0.14	150	0.47	0.39	0.12	127		45
Body ported	SYJA522-M5	N.O.	CIVI	0.66	0.45	0.18	186	0.66	0.45	0.18	186		45
Base mounted	SYJA514-01	N.C.	Rc 1/8	1.2	0.41	0.32	329	1.1	0.46	0.32	313	M5	75 (Without sub-
(with sub-plate) SYJA5	SYJA524-01	N.O.		1.3	0.37	0.33	346	1.2	0.48	0.34	347		plate 45)
Pady parted	SYJA712-01	N.C.	Rc 1/8	2.8	0.43	0.77	779	2.5	0.51	0.76	741		00
Body ported	SYJA722-01	N.O.		2.7	0.38	0.72	724	2.4	0.42	0.69	662		80
	SYJA714-01	NO	Rc 1/8	2.9	0.32	0.71	747	2.7	0.34	0.69	705	M5	100
Base mounted	SYJA714-02	N.C. Rc 1/4	Rc 1/4	3.0	0.31	0.74	768	2.6	0.33	0.66	674		130 (Without sub-
(with sub-plate)	SYJA724-01	N.O.	Rc 1/8	2.8	0.21	0.70	674	2.3	0.45	0.63	649		plate 80)
	SYJA724-02	IN.O.	Rc 1/4	2.7	0.31	0.68	691	2.3	0.48	0.64	665		plate 00)

Note) Model No. for base mounted style without sub-plate is SYJA5 $_{2}^{1}4$ , SYJA7 $_{2}^{1}4$ .


)) \*These values have been calculated according to ISO 6358 and represent the flow rate measured in standard conditions at an upstream pressure of 0.6MPa (relative pressure) and a differential pressure of 0.1MPa.




### Dimensions

### Series SYJA500 Body ported: SYJA5□2-M5(-F)

Base mounted: SYJA5□4-01□






### Series SYJ500/700 Made to Order




DIN Connector Conforming to EN-175301-803C (former DIN 43650C)

DIN connector type that conforms to the 8 mm pitch standards between DIN terminals.



### How to Order Pilot Valve Assembly



### **DIN Connector Part No**

SY100-82-1	
Voltage symbol	Model no.
24 VN	SY100-82-3-05
12 VN	SY100-82-3-06
100 VN	SY100-82-3-01
200 VN	SY100-82-3-02
110 VN	SY100-82-3-03
220 VN	SY100-82-3-04
	SY100-82-1 Voltage symbol 24 VN 12 VN 100 VN 200 VN 110 VN


### \land Caution

- 1. Use caution in wiring because it won't meet the IP65 (enclosure) standard if you use the other cord than prescribed heavy-duty cord of size (ø3.5 to ø7.5). Also be sure to tighten the ground nut and holding screw with the prescribed torque range. For how to use DIN terminal (wiring procedures, procedures for changing electrical entries, precautions, applicable cable, circuit diagram), refer to page 66. D type DIN connector with 9.4 mm pitch between terminals is not interchangeable.
- DIN connector except D type has the "N" indication in the end of voltage symbol. In case of DIN connector without light, "N" is not indicated. Please refer to the name plate to distinguish.
- 4. Dimensions are completely the same as D type connector.
  5. When exchanging the pilot valve assembly only, "V115-□D" is interchangeable with "V115-□Y". Do not replace V111 (G, H, L, M, W) to V115-□D/□Y (DIN terminal), and vice versa.


### Series SYJ300/500/700 Made to Order M8 Connector Conforming to IEC60947-5-2

M8 Connector type conforming to IEC60947-5-2 standard.

### How to Order Valve



### How to Order Pilot Valve Assembly




Order





(For detailed specifications, delivery and pricing, please contact SMC.)

### **Body Ported External Pilot**



 $\leq \Box$ 

• Entry is the same as standard products.

### **Operating Pressure Range MPa**

Operating pressure range	-100 kPa to 0.7
Pilot pressure range	0.15 to 0.7

### Dimensions

SYJ500: 8 mm longer in total length SYJ700: 8 mm longer in total length

#### **External Pilot Port**

Series	Port size
SYJ500, SYJ700	M5


#### **JIS Symbol**

#### 



## Series SYJ Safety Instructions

These safety instructions are intended to prevent a hazardous situation and/or equipment damage. These instructions indicate the level of potential hazard by labels of **"Caution", "Warning"** or **"Danger"**. To ensure safety, be sure to observe ISO 4414 <sup>Note 1)</sup>, JIS B 8370 <sup>Note 2)</sup> and other safety practices.



Note 2) JIS B 8370: General Rules for Pneumatic Equipment

### **Warning**

1. The compatibility of pneumatic equipment is the responsibility of the person who designs the pneumatic system or decides its specifications.

Since the products specified here are used in various operating conditions, their compatibility for the specific pneumatic system must be based on specifications or after analysis and/or tests to meet your specific requirements. The expected performance and safety assurance will be the responsibility of the person who has determined the compatibility of the system. This person should continuously review the suitability of all items specified, referring to the latest catalogue information with a view to giving due consideration to any possibility of equipment failure when configuring a system.

2. Only trained personnel should operate pneumatically operated machinery and equipment.

Compressed air can be dangerous if an operator is unfamiliar with it. Assembly, handling or repair of pneumatic systems should be performed by trained and experienced operators.

- 3. Do not service machinery/equipment or attempt to remove components until safety is confirmed.
  - 1. Inspection and maintenance of machinery/equipment should only be performed once measures to prevent falling or runaway of the driver objects have been confirmed.
  - 2. When equipment is to be removed, confirm the safety process as mentioned above. Cut the supply pressure for this equipment and exhaust all residual compressed air in the system.
  - 3. Before machinery/equipment is restarted, take measures to prevent shooting-out of cylinder piston rod, etc.
- 4. Contact SMC if the product is to be used in any of the following conditions:
  - 1. Conditions and environments beyond the given specifications, or if product is used outdoors.
  - 2. Installation on equipment in conjunction with atomic energy, railway, air navigation, vehicles, medical equipment, food and beverages, recreation equipment, emergency stop circuits, clutch and brake circuits in press applications, or safety equipment.
  - 3. An application which has the possibility of having negative effects on people, property, or animals, requiring special safety analysis.

# **3 Port Solenoid Valves/Common Precautions 1**

Be sure to read before handling.

#### Design

### \land Warning

### 1. Actuator drive

When an actuator, such as a cylinder, is to be driven using a valve, take appropriate measures to prevent potential danger caused by actuator operation.

### 2. Effect of back pressure when using a manifold

Use caution when valves are used on a manifold, as actuator malfunction due to back-pressure may occur.

Note: Extra care should be taken when driving a single acting cylinder. Take measures to prevent potential malfunction.

### 3. Holding of pressure (including vacuum)

Since valves are subject to air leakage, they cannot be used for applications such as holding pressure (including vacuum) in a pressure vessel.

#### 4. Cannot be used as an emergency shut off valve, etc.

The valves presented in this catalogue are not designed for safety applications such as an emergency shut off valve. If the valves are used in this type of system, other reliable safety assurance measures should also be adopted.

#### 5. Maintenance space

The installation should allow sufficient space for maintenance activities (removal of valve, etc.).

### 6. Release of residual pressure

Provide a residual pressure release function for maintenance purpose.

### 7. Vacuum applications

When a valve is used for vacuum switching, etc., take measures against the suction of external dust or other contaminants from vacuum pads and exhaust ports, etc. Moreover, an external pilot type valve should be used in this case. Contact SMC in case of an internal pilot type or air operated valve, etc.

#### 8. Ventilation

When a valve is used inside a sealed control panel, etc., provide ventilation to prevent a pressure increase caused by exhausted air inside the control panel or temperature rise caused by the heat generated by the valve.

#### Selection

### **M** Warning

### 1. Confirm the specification.

The products presented in this catalogue are designed only for use in compressed air systems (including vacuum). Do not operate at pressures or temperatures, etc., beyond the range of specifications, as this can cause damage or malfunction. (Refer to specifications.)

Contact SMC when using a fluid other than compressed air (including vacuum).

### 2. Extended periods of continuous energisation

- Continuous energisation of the valve for extended periods of time may have an adverse effect on the solenoid valve performance and the peripheral equipment due to temperature rises caused by the heat generation of the coil. Consult with SMC if valves will be continuously energised for extended periods of time or the energised period per day will be longer than the de-energised period. It is also possible to shorten the energisation period by using valves of the N.O. (normally open) type.
- · When solenoid valves are mounted in a control panel, employ measures to radiate excess heat, so that temperatures remain within the valve specification range. Use special caution when three or more stations sequentially aligned on the manifold are continuously energised since this will cause a drastic temperature rise.


(As for AC specifications, since the applicable products are ready to provide separately, contact SMC.)

#### Selection

### A Caution

### 1. Leakage voltage

When using a resistor in parallel with the switching element or using a C-R element (surge voltage suppressor) for protection of the switching element, note that leakage voltage will



increase due to leakage current flowing through the resistor or C-R element. Limit the amount of residual leakage voltage to the following value:

With DC coil : 3% or less of rated voltage

With AC coil : 8% or less of rated voltage

### 2. Solenoid valve drive for AC with solid state output (SSR, TRIAC output, etc.)

### 1) Current leakage

When using a snubber circuit (C-R element) for surge protection of the output element, a very small electric current will still continue to flow in spite of the OFF state. This results in the valve not returning. In the cases when exceeding the tolerance as shown above, take measures to install a bleeder resistor.

2) Minimum load allowable amount (Min. load current) When the consumption current of a valve is less than the output element's minimum load allowable volume or the margin is small, the output element may not be switched normally. Please confirm SMC.

### 3. Surge voltage suppressor

If a surge protection circuit contains non-ordinary diodes such as Varistor, a residual voltage that is in proportion to the protective elements and the rated voltage will remain. Therefore, give consideration to surge voltage protection of the controller. In the case of diodes, the residual voltage is approximately 1 V.

### 4. Use in low temperature environments

Unless otherwise indicated in the specifications for each valve, operation is possible to -10°C, but appropriate measures should be taken to avoid solidification or freezing of drainage and moisture, etc.

### 3 Port Solenoid Valves/Common Precautions 2 Be sure to read before handling.

#### Selection

### **A** Caution

### 5. Operation for air blowing

When using a solenoid valve for air blow, use an external pilot type.

Take note that when internal pilots and external pilots are used on the same manifold, the pressure drop caused by the air blowing can have an effect on the internal pilot type valves. Moreover, when compressed air within the pressure range of the established specifications is supplied to the external pilot port, and a double solenoid valve is used for air blowing, the solenoids should normally be energised when air is being blown.

### 6. Mounting orientation

Rubber seal: Refer to the specifications of each series.

### Mounting

### **A** Warning

### 1. If air leakage increases or equipment does not operate properly, stop operation.

Check mounting conditions when air and power supplies are connected. Initial function and leakage tests should be performed after installation.

#### 2. Instruction manual

Mount and operate the product after reading the manual carefully and understanding its contents.

Also keep the manual where it can be referred to as necessary.

### 3. Painting and coating

Warnings or specifications printed or pasted on the product should not be erased, removed or covered up. Consult with SMC if paint is to be applied to resinous parts, as this may have an adverse effect due to the paint solvent.

### Piping


### **A**Caution

### 1. Preparation before piping

Before piping is connected, it should be thoroughly blown out with air (flushing) or washed to remove chips, cutting oil and other debris from inside the pipe.

#### 2. Wrapping of sealant tape

When connecting pipes and fittings, etc., be sure that chips from the pipe thread and sealing materials do not get inside the valve. Furthermore, when pipe tape is used, leave 1.5 to 2 thread ridges exposed at the end of the threads.



#### Piping

### 3. Screwing in fittings

When connecting fittings to valves, tighten as indicated below. 1) For M5 type

- (1) When using SMC fittings, follow the guidelines below. M5: After tightening by hand, tighten an additional 1/6 turn with a tightening tool. However, if miniature fittings are used, tighten an additional 1/4 turn with a tightening tool after tightening by hand. For fittings with gaskets in 2 locations, e.g., universal elbow or universal tee, tighten an additional 1/2 turn.
- Note) If fittings are over-tightened, air leakage may result due to breaking of fitting threads or deformation of the gaskets. However, if fittings are not tightened sufficiently, loosening of the threads and air leakage and may occur.
- (2) When fittings other than SMC fittings are used, follow the instructions of the respective fitting manufacturer.
- 2) For threads

#### **Tightening Torque for Piping**

<u> </u>	
Connection threads	Proper tightening torque N·m
1/8	7 to 9
1/4	12 to 14

### 4. Connection of piping to products

When connecting piping to a product, refer to its instruction manual to avoid mistakes regarding the supply port, etc.

#### Wiring

### **▲** Caution

### 1. Polarity

When connecting power to a DC specification solenoid valve equipped with (indicator light) surge voltage suppressor, confirm whether or not there is polarity.

If there is polarity, take note of the following points.

Without built-in diode to protect polarity (including power saving circuit):

If a mistake is made regarding polarity, the diode in the valve, the control device switching element or power supply equipment, etc., may burn out.

With diode to protect polarity:

If a mistake is made regarding polarity, it will not be possible to switch the valve.

#### 2. Applied voltage

When electric power is connected to a solenoid valve, be careful to apply the proper voltage. Improper voltage may cause malfunction or coil damage.

#### 3. Confirm the connections.

After completing the wiring, confirm that the connections are correct.

# 3 Port Solenoid Valves/Common Precautions 3

Be sure to read before handling.

### Lubrication

### **A**Caution

#### 1. Lubrication

- 1) The valve has been lubricated for life at the factory, and does not require any further lubrication.
- 2) In the event that it is lubricated, use class 1 turbine oil (without additives), ISO VG32.

However, once lubrication is applied it must be continued, as loss of the original lubricant may lead to malfunction. Contact SMC regarding class 2 turbine oil (with additives), ISO VG32.

### Air Supply

### **Warning**

### 1. Use clean air.

Do not use compressed air which contains chemicals, synthetic oils containing organic solvents, salts or corrosive gases, etc., as this can cause damage or malfunction.

### **A**Caution

### 1. Install air filters.

Install air filters close to valves at their upstream side. A filtration degree of 5  $\mu m$  or less should be selected.

2. Install an air dryer, after cooler or Drain Catch (water separator), etc.

Air that includes excessive drainage may cause malfunction of valves and other pneumatic equipment. To prevent this, install an air dryer, after-cooler or water separator, etc.

3. If excessive carbon dust is generated, eliminate it by installing mist separators at the upstream side of valves.

If excessive carbon dust is generated by the compressor, it may adhere to the inside of valves and cause malfunction.

Refer to "SMC Best Pneumatics" catalogue for compressed air quality.

### **Operating Environment**

### **A** Warning

- 1. Do not use valves in atmospheres of corrosive gases, chemicals, salt water, water or steam or where there is direct contact with any of these.
- 2. Products with IP65 enclosures (based on IEC60529) are protected against dust and water, however, these products cannot be used in water.

Take measures to prevent water and dust from coming from the exhaust port.

- 3. Products compliant to IP65 satisfy the specifications by mounting each product properly. Be sure to read the Specific Product Precautions for each product.
- 4. Do not use in an explosive atmosphere.

### **Operating Environment**

- 5. Do not use in locations subject to vibration or impact. Confirm the specifications in the main section of the catalogue.
- 6. A protective cover, etc., should be used to shield valves from direct sunlight.
- 7. Shield valves from radiated heat generated by nearby heat sources.
- 8. Employ suitable protective measures in locations where there is contact with water droplets, oil or welding spatter, etc.
- 9. When solenoid valves are mounted in a control panel or are energised for extended periods of time, employ measures to radiate excess heat, so that temperatures remain within the valve specification range.

### Maintenance

### **Warning**

1. Perform maintenance procedures as shown in the instruction manual.

If handled improperly, malfunction or damage of machinery or equipment may occur.

2. Equipment removal and supply/exhaust of compressed air

When equipment is removed, first confirm that measures are in place to prevent dropping of work pieces and run-away of equipment, etc. Then cut the supply pressure and power, and exhaust all compressed air from the system using its residual pressure release function. When the equipment is to be started again after remounting or replacement, first confirm that measures are in place to prevent lurching of actuators, etc., and then confirm that the equipment is operating normally.

### 3. Low frequency operation

Valves should be switched at least once every 30 days to prevent malfunction. (Use caution regarding the air supply.)

#### 4. Manual override operation

When the manual override is operated, connected equipment will be actuated. Confirm safety before operating.

### **A**Caution

### 1. Drain flushing

Remove drainage from air filters regularly.



Be sure to read before handling. Refer to back page 1 through to 4 for Safety Instructions and Common Precautions.

#### Manual Override Operation

### \land Warning

When the manual override is operated, connected equipment will be actuated. Confirm safety before operating.

### Non-locking push type [Standard]

Press in the direction of the arrow



### Push-turn slotted locking type [Type D]

While pressing, turn in the direction of the arrow. If it is not turned, it can be operated the same way as the nonlocking type.

Locked position

Locked position



### ▲ Caution

When operating the locking type D with a screw driver, turn it gently using a watchmakers screw driver. [Torque: Less than 0.1  $N \cdot m$ ]

### ■ Push-turn locking lever type [Type E]

While pressing, turn in the direction of the arrow. If it is not turned, it can be operated the same way as the nonlocking type.





When locking the manual override on the push-turn locking types (D, E), be sure to push it down before turning. Turning without first pushing it down can cause damage to the manual override and trouble such as air leakage, etc.

### Solenoid Valve for 200 V, 220 VAC Specifications

### \land Warning

Solenoid valves with DIN terminal connector AC specifications have a built-in rectifier circuit in the pilot section to operate the DC coil.

With 200 V, 220 VAC specification pilot valves, this built-in rectifier generates heat when energised. The surface may become hot depending on the energised condition; therefore, do not touch the solenoid valves.

### Common Exhaust Type for Main and Pilot Valve

### \land Caution

Pilot air is exhausted through the main valve body rather than directly to atmosphere.

- Suitable for applications where exhausting the pilot valve to atmosphere would be detrimental to the surrounding working environment.
- For use in extremely dirty environments where there is the possibility that dust could enter the pilot exhaust and damage the valve.

Ensure that the piping of exhaust air is not too restrictive.

#### Bracket

### **▲** Caution

For bracket attached styles of SYJ300, do not use it without bracket.



Be sure to read before handling.


Refer to back page 1 through to 4 for Safety Instructions and Common Precautions.

#### How to Use Plug Connector

### A Caution

### 1. Attaching and detaching connectors


- To attach a connector, hold the lever and connector unit between your fingers and insert straight onto the pins of the solenoid valve so that the lever's pawl is pushed into the groove and locks.
- To detach a connector, remove the pawl from the groove by pushing the lever downward with your thumb, and pull the connector straight out.



### 2. Crimping of lead wires and sockets

Strip 3.2 to 3.7 mm at the end of the lead wires, insert the ends of the core wires evenly into the sockets, and then crimp with a crimping tool. When this is done, take care that the coverings of the lead wires do not enter the core wire crimping area.

Use an exclusive crimping tool for crimping. (Contact SMC for special crimping tools.)




### 3. Attaching and detaching sockets with lead wires

#### Attaching

Insert the sockets into the square holes of the connector (+, - indication), and continue to push the sockets all the way in until they lock by hooking into the seats in the connector. (When they are pushed in, their hooks open and they are locked automatically.) Then confirm that they are locked by pulling lightly on the lead wires.

#### Detaching

To detach a socket from a connector, pull out the lead wire while pressing the socket's hook with a stick having a thin tip (approx. 1 mm). If the socket will be used again, first spread the hook outward.



### Plug Connector Lead Wire Length

### ▲ Caution

Standard length is 300 mm, but the following lengths are also available.

#### How to Order Connector Assembly

For DC: **SY100 – 30 – 4A –** 

Lead wire length

Without lead wire: SY100 - 30 - A
(with connector and 2 of sockets only)

#### How to Order

Include the connector assembly part number together with the part number for the plug connector's solenoid valve without connector.


EX.) In case of 2000 mm of lead wire

For DC

SYJ312-5LO-M3 SY100-30-4A-20



Be sure to read before handling. Refer to back page 1 through to 4 for Safety Instructions and Common Precautions.





Be sure to read before handling.

Refer to back page 1 through to 4 for Safety Instructions and Common Precautions.

#### Surge Voltage Suppressor


#### <For AC>

(There is no "S" type because the generation of surge voltage is prevented by a rectifier.)

### A Caution

### DIN Terminal

#### With light (DZ)



Note) Surge voltage suppressor of varistor has residual voltage corresponding to the protective element and rated voltage; therefore, protect the controller side from the surge. The residual voltage of the diode is approximately 1 V.

### How to Use DIN Terminal

### **A** Caution

### Connection

- 1. Loosen the holding screw and pull the connector out of the solenoid valve terminal block.
- 2. After removing the holding screw, insert a flat head screwdriver, etc. into the notch on the bottom of the terminal block and pry it open, separating the terminal block and the housing.
- 3. Loosen the terminal screws (slotted screws) on the terminal block, insert the cores of the lead wires into the terminals according to the connection method, and fasten them securely with the terminal screws.
- 4. Secure the cord by fastening the ground nut.

### A Caution

When making connections, take note that using other than the supported size ( $\emptyset$ 3.5 to  $\emptyset$ 7) heavy duty cord will not satisfy IP65 (enclosure) standards. Also, be sure to tighten the ground nut and holding screw within their specified torque ranges.

#### Changing the entry direction

After separating the terminal block and housing, the cord entry can be changed by attaching the housing in the desired direction (4 directions at  $90^{\circ}$  intervals).

\* When equipped with a light, be careful not to damage the light with the cord's lead wires.

### How to Use DIN Terminal

### **A** Caution


### Precautions

Plug in and pull out the connector vertically without tilting to one side.

### Compatible cable

Cord O.D.: ø3.5 to ø7

(Reference) 0.5 mm<sup>2</sup>, 2-core or 3-core, equivalent to JIS C 3306



### **Solenoid Valve Mounting**

### \land Caution

Mount it so that there is no slippage or deformation in gaskets, and tighten with the tightening torque as shown below.

Model	Thread size	Tightening torque
SYJ300	M1.7	0.12 N•m
SYJ500	M2.5	0.45 N•m
SYJ700	M3	0.8 N•m

#### **DIN Connector Part No.**


SY100-61-1


### **▲** Caution

Without light

with light		
Rated voltage	Voltage symbol	Model no.
24 VDC	24 V	SY100-61-3-05
12 VDC	12 V	SY100-61-3-06
100 VAC	100 V	SY100-61-2-01
200 VAC	200 V	SY100-61-2-02
110 VAC	110 V	SY100-61-2-03
220 VAC	220 V	SY100-61-2-04

#### **Circuit Diagram with Light**





Note) Refer to page 57 for DIN connector (Y) conforming to EN-175301-803C (former DIN 43650C).





Be sure to read before handling.

Refer to back page 1 through to 4 for Safety Instructions and Common Precautions.


### **Connector Assembly with Cover**

### **≜**Caution

#### Connector assembly with dust proof protective cover.

- Effective to prevention of short circuit failure due to the entry of foreign matter into the connector.
- Chloroprene rubber for electrical use, which provides outstanding weather resistance and electrical insulation, is used for the cover material. However, do not allow contact with cutting oil, etc.
- Simple and unencumbered appearance by adopting round-shaped cord.

#### How to Order SY100-68-A-Lead wire length 300 mm 6 600 mm 10 1000 mm 15 1500 mm 20 2000 mm 25 2500 mm 30 3000 mm 50 5000 mm **Connector Assembly with Cover: Dimensions**



#### How to Order

Enter the part number for a plug connector solenoid valve without connector together with the part number for a connector assembly with cover.

- Ex. 1) Lead wire length of 2000 mm SYJ312-5LOZ-M3-Q SY100-68-A-20
- Ex. 2) Lead wire length of 300 mm (standard) SYJ312-5LPZ-M3-Q

Symbol for connector assembly with cover

\* In this case, the part number for the connector assembly with cover is not required.

#### **M8** Connector

### **≜**Caution

1. M8 connector types have an IP65 (enclosure) rating, offering protection from dust and water. However please note: these products are not intended for use in water.

Select a SMC connector cable (V100-49-1-□) or a FA sensor type connector, with M8 threaded 3 pin specifications conforming to Nippon Electric Control Equipment Association Standard, NECA4202 (IEC60947-5-2). Make sure the connector O.D. is 10.5 mm or less when used with the Series SYJ300 manifold. If more than 10.5 mm, it cannot be mounted due to the size.

- 2. Do not use a tool to mount the connector, as this may cause damage. Only tighten by hand. (0.4 to 0.6 Nm)
- 3. The excessive stress on the cable connector will not be able to satisfy the IP65 rating. Please use caution and do not apply a stress of 30 N or greater.

### **▲** Caution

Failure to meet IP65 performance may result if using alternative connectors than those shown above, or when insufficiently tightened.

Connector cable mounting



Note) Connector cable should be mounted in the correct direction. Make sure that the arrow symbol on the connector is facing the triangle symbol on the valve when using SMC connector cable (V100-49-1-□). Be careful not to squeeze it in the wrong direction, as problems such as pin damage may occur.



Be sure to read before handling.

Refer to back page 1 through to 4 for Safety Instructions and Common Precautions.


#### M8 Connector

### Connector cable

• M8 connector cable for M8 can be ordered as follows:

#### How to Order


1. To order solenoid valve and connector cable at the same time. (Connector cable will be included in the shipment of the solenoid valve.)




- W2, WA2: Cable length 500 mm
- W3, WA3: Cable length 1000 mm
- W4, WA4: Cable length 2000 mm W7, WA7: Cable length 5000 mm
- Ex. 1) Cable length: 300 mm SYJ312-5W1ZE-M3-Q

Symbol for electrical entry

2. To order connector cable only



Cable length (L)	No.
300 mm	V100-49-1-1
500 mm	V100-49-1-2
1000 mm	V100-49-1-3
2000 mm	V100-49-1-4
5000 mm	V100-49-1-7



#### How to Measure the Flow Rate


### **∕**∧Caution

Refer to pages 69 and 70: How to measure the flow rate.


### **Replacement of Pilot Valve**

### ▲Caution

Pilot valves in this series are improved to provide excellent energy saving results. However following this improvement, these new valves are no longer compatible with the conventional pilot valve used at the interface. Consult with SMC when you need to exchange these pilot valves, in the case of manual override (marked in orange) of the adapter plate.



#### **Conventional type**





#### **EUROPEAN SUBSIDIARIES:**

Austria

SMC Pneumatik GmbH (Austria). Girakstrasse 8, A-2100 Korneuburg Phone: +43 2262-62280, Fax: +43 2262-62285 E-mail: office@smc.at http://www.smc.at



Belgium

SMC Pneumatics N.V./S.A. Nijverheidsstraat 20, B-2160 Wommelgem Phone: +32 (0)3-355-1464, Fax: +32 (0)3-355-1466 E-mail: post@smcpneumatics.be http://www.smcpneumatics.be



SMC Industrial Automation Bulgaria EOOD 16 kliment Ohridski Blvd., fl.13 BG-1756 Sofia Phone:+359 2 9744492, Fax:+359 2 9744519 E-mail: office@smc.bg http://www.smc.ba



### Croatia

SMC Industrijska automatika d.o.o. Crnomerec 12, 10000 ZAGREB Phone: +385 1 377 66 74, Fax: +385 1 377 66 74 E-mail: office@smc.hr http://www.smc.hr



### **Czech Republic**

SMC Industrial Automation CZ s.r.o. Hudcova 78a, CZ-61200 Brno Phone: +420 5 414 24611, Fax: +420 5 412 18034 E-mail: office@smc.cz http://www.smc.cz



### SMC Pneumatik A/S Knudsminde 4B, DK-8300 Odder Phone: +45 70252900, Fax: +45 70252901

E-mail: smc@smc-pneumatik.dk http://www.smcdk.com



#### Estonia SMC Pneumatics Estonia OÜ Laki 12, 106 21 Tallinn Phone: +372 6510370, Fax: +372 65110371 E-mail: smc@smcpneumatics.ee http://www.smcpneumatics.ee



### Phone: +358 207 513513, Fax: +358 207 513595 E-mail: smcfi@smc.fi http://www.smc.fi

France

SMC Pneutatique, S.A. 1, Boulevard de Strasbourg, Parc Gustave Eiffel Bussy Saint Georges F-77607 Marne La Vallee Cedex 3 Phone: +33 (0)1-6476 1000, Fax: +33 (0)1-6476 1010 E-mail: contact@smc-france.fr http://www.smc-france.fr



SMC Pneumatik GmbH Boschring 13-15, D-63329 Egelsbach Phone: +49 (0)6103-4020, Fax: +49 (0)6103-402139 E-mail: info@smc-pneumatik.de

http://www.smc-pneumatik.de

#### Greece

SMC Hellas EPE Anagenniseos 7-9 - P.C. 14342. N. Philadelphia, Athens Phone: +30-210-2717265, Fax: +30-210-2717766 E-mail: sales@smchellas.gr http://www.smchellas.gr



Hungary SMC Hungary Ipari Automatizálási Kft. Budafoki ut 107-113, H-1117 Budapest Phone: +36 1 371 1343, Fax: +36 1 371 1344 E-mail: office@smc.hu http://www.smc.hu



#### Ireland SMC Pneumatics (Ireland) Ltd. 2002 Citywest Business Campus, Naas Road, Saggart, Co. Dublin Phone: +353 (0)1-403 9000, Fax: +353 (0)1-464-0500 E-mail: sales@smcpneumatics.ie http://www.smcpneumatics.ie

Italv SMC Italia S.p.A



Latvia SMC Pneumatics Latvia SIA Smerla 1-705, Riga LV-1006 Phone: +371 781-77-00, Fax: +371 781-77-01 E-mail: info@smclv.lv http://www.smclv.lv

E-mail: mailbox@smcitalia.it



SMC Pneumatics Lietuva, UAB Oslo g.1, LT-04123 Vilnius Phone: +370 5 264 81 26, Fax: +370 5 264 81 26

### Netherlands

SMC Pneumatics BV De Ruyterkade 120, NL-1011 AB Amsterdam Phone: +31 (0)20-5318888, Fax: +31 (0)20-5318880 E-mail: info@smcpneumatics.nl http://www.smcpneumatics.nl



SMC Pneumatics Norway A/S

Vollsveien 13 C, Granfos Næringspark N-1366 Lysaker Tel: +47 67 12 90 20, Fax: +47 67 12 90 21 E-mail: post@smc-norge.no http://www.smc-norge.no



SMC Industrial Automation Polska Sp.z.o.o. ul. Poloneza 89, PL-02-826 Warszawa, Phone: +48 22 211 9600, Fax: +48 22 211 9617 E-mail: office@smc.pl http://www.smc.pl



### Portugal

SMC Sucursal Portugal, S.A. Rua de Eng<sup>a</sup> Ferreira Dias 452, 4100-246 Porto Phone: +351 22-610-89-22, Fax: +351 22-610-89-36 E-mail: postpt@smc.smces.es http://www.smces.es



SMC Romania srl

Str Frunzei 29, Sector 2, Bucharest Phone: +40 213205111, Fax: +40 213261489 F-mail: smcromania@smcromania ro http://www.smcromania.ro



SMC Pneumatik LLC 4B Sverdlovskaja nab, St. Petersburg 195009 Phone.:+7 812 718 5445. Fax:+7 812 718 5449 -mail: info@smc-pneumatik.ru http://www.smc-pneumatik.ru



http://www.smc.sk



Slovenia SMC industrijska Avtomatika d.o.o. Mirnska cesta 7, SLO-8210 Trebnje Phone: +386 7 3885412 Fax: +386 7 3885435 E-mail: office@smc.si



SMC España, S.A. Zuazobidea 14, 01015 Vitoria Phone: +34 945-184 100, Fax: +34 945-184 124 E-mail: post@smc.smces.es http://www.smces.es



Sweden SMC Pneumatics Sweden AB Ekhagsvägen 29-31, S-141 71 Huddinge Phone: +46 (0)8-603 12 00, Fax: +46 (0)8-603 12 90 E-mail: post@smcpneumatics.se http://www.smc.nu



SMC Pneumatik AG Dorfstrasse 7, CH-8484 Weisslingen Phone: +41 (0)52-396-3131, Fax: +41 (0)52-396-3191 E-mail: info@smc.ch http://www.smc.ch




Turkey Entek Pnömatik San. ve Tic Ltd. Sti. Perpa Tic. Merkezi Kat: 11 No: 1625, TR-80270 Okmeydani Istanbul Phone: +90 (0)212-221-1512, Fax: +90 (0)212-221-1519 E-mail: smc-entek@entek.com.tr http://www.entek.com.tr



UK SMC Pneumatics (UK) Ltd Vincent Avenue, Crownhill, Milton Keynes, MK8 0AN Phone: +44 (0)800 1382930 Fax: +44 (0)1908-555064 E-mail: sales@smcpneumatics.co.uk http://www.smcpneumatics.co.uk

http://www.smc.eu http://www.smcworld.com









Slovakia SMC Priemyselná Automatizáciá, s.r.o. Námestie Matina Benku 10, SK-81107 Bratislava Phone: +421 2 444 56725, Fax: +421 2 444 56028 E-mail: office@smc.sk



http://www.smc.si

**OTHER SUBSIDIARIES WORLDWIDE:** ARGENTINA, AUSTRALIA, BOLIVIA, BRASIL, CANADA, CHILE,

CHINA, HONG KONG, INDIA, INDONESIA, MALAYSIA, MEXICO, NEW ZEALAND, PHILIPPINES, SINGAPORE, SOUTH KOREA, TAIWAN, THAILAND, USA, VENEZUELA

#### Specifications are subject to change without prior notice and any obligation on the part of the manufacturer.